

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 27.09.2024

It is certified that an inspection team headed by Ratan Gopal Das, Sanitary Inspector

(Name of Officers with designation) from South Dum Dum Municipality PHED

inspected the Indira Gandhi Memorial High School, 456 P.K. Ganga Road, Dum Dum, West Bengal

(Name & Address of the school) on 27/09/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. G/SEP/24/40 dated 27.09.2024

 Water Testing Lab, 24 Pgs, Sub District
Lab, Govt. of West Bengal

(PHED Lab) certified that the

Indira Gandhi Memorial High School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal: 

Name : Ratan Gopal Das

Designation : Nodal Officer (Dengue)

Name & Address of the Office / Department : South Dum Dum Municipality

To Indira Gandhi Memorial High School

 456, P.K. Ganga Road, Dum Dum, Kolkata - 700028

(Name & Address of the Institution)

Sanitary Inspector
South Dum Dum Municipality

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

NATIONAL DRINKING WATER QUALITY TESTING MONITORING AND SURVEILLANCE PROGRAMME

Collaborative effort of Public Health Engineering Dte., Govt. of W.B., Panchayet & Rural Development Department of Govt. of W.B.,
Department of Health & Family Welfare, Govt. of W.B.

Implemented by :-

WATER TESTING LABORATORY**PASCHIM BANGA VIGYAN MANCHA**

North 24 Parganas District Committee

SUB DISTRICT LABORATORY, GOVERNMENT of WEST BENGAL, LAB ID: 001700

N/37/5, Banamalipur Road, Binoy Dey, Sushanta Pal Sarani, Barasat

email : watertestinglab.pbvm@gmail.com

Name of the Owner :	UDAY RAJ SINGH	Date of Collection:	18.09.2024
		Sample collected from:	Collected by lab Personnel / Aqua Guard
Address of the Owner :	Indira Gandhi Memorial High School, Dum Dum, Kol - 28	Sample received on:	18.09.2024
		Testing Start Date	18.09.2024
		Testing End Date	19.09.2024

Indian Standards for Drinking Water (IS-10500:2012) & Testing result of the water sample :-**A. Physical Parameters:**

	Methodology	Desirable Limit	Permissible Limit	Test Result
Colour			-	NOT AVAILABLE
Odour				NOT AVAILABLE
Temperature (°C)	Thermometry			29.2
pH	ELECTROMETRIC	6.50-8.50	No relaxation	6.03
Dissolved Solids, mg/l	TDS Meter	500	2000	20
Turbidity, NTU	NEPHALOMETRIC	1	5	0.31

B. General Parameters :

IRON, (as Fe) mg/l	PHOTOMETRY	1	No relaxation	0.0980
Manganese, mg/L	PHOTOMETRY	0.1	0.3	NOT TESTED
Total Hardness. (as CaCO ₃) m	TITRIMETRIC	300	600	16

C. Toxic Substances :

TOTAL ARSENIC mg/L	PHOTOMETRY	0.01	No relaxation	0
--------------------	------------	------	---------------	---

D. Bacteriological Quality:

TOTAL COLIFORM per 100 ml	MFT	0	No relaxation	0
FAECAL COLIFORM per 100 ml	MFT	0	No relaxation	0

Note :**Remark :**

Epermi
ETISHA PERVIN
(Chemist)

Rimpa
RIMPA GUIN
(Bacteriologist)

*The figures indicated under the column "Desirable Limit" are the limits up to which water is generally acceptable to the consumers.